



**PAVUS, a.s.**

**Notified Body No. 1391**

**Prosecká 412/74, 190 00 Praha 9 - Prosek**

**Decision No. 27/2013-CPR of 13. 12. 2013**

## **CERTIFICATE OF CONSTANCY OF PERFORMANCE**

**No. 1391-CPR-0011/2014**

In compliance with Regulation 305/2011/EU of European Parliament and of the Council of 9 March 2011 (the Construction Product regulation or CPR), this certificate applies to the construction product:

### **Fire damper FDMB**

#### **Technical parameters of the product:**

are stated in the Annex No. 1 of this Certificate of constancy of performance and related documentation

#### **Intended use of the product in buildings:**

Fire dampers are used in conjunction with partitions to maintain fire compartments and protect means of escape in case of fire in heating, ventilation and air conditioning (HVAC) systems in buildings, under methods of use and installation conditions stated in certification report and related documentation. All fire dampers close automatically in response to raised temperatures indicating fire.

**produced by or for:**

**MANDÍK, a.s.**

**Dobříšská 550, 267 24 Hostomice, Czech republic, IdNo. 26718405**

**and produced in the manufacturing plant:**

**MANDÍK, a.s.**

**Dobříšská 550, 267 24 Hostomice, Czech republic**


This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:


**EN 15650:2010**

**under system 1 for the performances set out in this certificate are applied and that  
the construction product fulfils all the prescribed requirements for these  
performances.**

This certificate was first issued on 29th August 2012 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performances of the declared essential characteristics, do not change, and the construction product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the product certification body. This Certificate replaces and cancels ES certificate of conformity No. 1391-CPD-0113/2012 of 29th August 2012 issued by NB 1391.

In Prague 27th June 2014



  
**Ing. Jaroslav Dufek**  
Managing Director PAVUS, a.s.  
Notified Body No. 1391



**Technical parametres of the product \*)**

External dimension of the element: - circular from min. diameter 160 mm to max. 630 mm  
 - square (w x h) from min. (160 x 160) mm to max. (1 000 x 500) mm

Construction length: min. 375 mm, max. 500 mm

Starting devices and drives: - fuse safety lock 72C/95C with closing spring  
 - Bellimo - spring drive with starting device 72C/95C  
 - Gruner - spring drive with starting device 72C/95C  
 - Schischek - spring drive with starting device 72C/95C  
 All used marks of drives fulfil 10 000 cycles according to EN 15650.

Material versions: - galvanized sheet metal,  
 - stainless sheet metal,  
 - painted sheet metal.

Leak tightness of the damper according to EN 1751:  
 - over blade min. class 2  
 - over coat min. class C

The classification according to EN 13501-3+A1:

**EI 120 (ve ho i↔o) S**

**EI 90 (ve ho i↔o) S**

**Assessed properties of the product**

Essential characteristics	Requirement clauses in EN 15650	Requirement	Conformity Assessment
Nominal activation conditions/sensitivity:	4.2.1.2	EN 15650, Art. 4.2.1.2	conforms
- sensing element load bearing capacity	4.2.1.2.2	EN 15650, Art. 5.2.5	conforms
- sensing element response temperature	4.2.1.2.3	EN 15650, Art. 5.2.5	conforms
Response delay (response time):	4.2.1.3	EN 1366-2, Art. 10.4.6	conforms
- closure time			
Operational reliability:	4.3.1, a)	The fire damper conforms to cycle test if 50 cycles are done prior to the fire test	conforms
- cycling			
Fire resistance			
- integrity	4.1.1, a)	E	conforms
- insulation	4.1.1, b)	EI	conforms
- smoke leakage	4.1.1, c)	ES/EIS	conforms
- mechanical stability (under E)	4.1.1, a)	-	conforms
- maintenance of the cross section (under E)	4.1.1, a)	-	conforms
Durability of response delay:	4.2.1.2.2	EN 15650, Art. 4.2.1.2	conforms
- sensing element response to temperature and load bearing capacity	4.2.1.2.3		
Durability of operational reliability:	4.3.3.2	EN 15650, Annex C.3.2	conforms
- open and closing cycle tests			
Resistance against corrosion	4.2.2 Annex B	Increased resistance against corrosion - Salt spray exposure test (EN 60068-2-52)	conforms

\*) Detailed technical parametres and conditions of final classification according to EN 13501-3+A1 are stated in the Certification Report No. P-1391-CPR-0011/2014 of 27th June 2014.

Fire damper FDMB fulfils also hygienics standards EN 13053, EN 13779, VDI 6022-1, VDI 2167-1, DIN 1946-4.

Fire damper FDMB may be produced and placed on the market also with trade name PKTM III or BSK-B-90.


1391 MANDIK a.s., Dobříšská 550, 267 24 Hostomice, Czech rep. 14 1391 – CPR - 0011/2014
EN 15650 Fire damper type/model: Fire damper FDMB
Classification EI 90 (ve ho i↔o) S EI 120 (ve ho i↔o) S



  
**Ing. Jaroslav Dufek**  
 Managing Director PAVUS, a.s.  
 Notified Body No.1391