

1.	Unique identification code of the product-type	FDML
2.	Products	Dampers – Fire dampers
	Intended use	Fire safety. To be used in conjunction with partitions to maintain fire compartments in heating, ventilating and air conditioning installations.
	Technical documentation – product information, instruction for installation and maintenance, safety information	Technical specifications TPM 130/17
3.	Manufacturer	MANDÍK, a.s. Dobříšská 550, 26724 Hostomice, Czech Republic ID 26718405, tel. +420 311 706 706 mandik@mandik.cz , www.mandik.com
5.	System of AVCP	System 1
6.	Harmonised standard	EN 15650:2010
	Notified body	Notified body No. 1391 PAVUS, a.s., Prosecká 412/74, 190 00 Praha 9 – Prosek
	Output documents of the notified body	Certificate of Constancy of Performance No. 1391-CPR-2018/0025/O1 Assessment Report of Performance of Construction Product No. P-1391-CPR-2018/0025/O1

7a.	Declared performances – fire resistance classification Essential characteristics in accordance with EN 15650:2010, art. 4.1.1	
	<i>Fire separating construction, location of the damper</i>	<i>Installation type, installation system</i>
	<i>Performance – class of fire resistance</i>	
	Solid wall construction – 100 mm min. wall thickness – damper in the wall – connected to duct with forced air flow	Mortar or gypsum. For wall thicknesses inferior to 150 mm, fire resistant cover plates used. ¹⁾ Mineral wool min 140. kg/m ³ with fire stop mastic min. 1 mm and fire stop coating min. 1 mm. For wall thicknesses inferior to 150 mm, fire resistant cover plates used. ¹⁾
	Gypsum plasterboard wall construction – 100 mm min. wall thickness – damper in the wall – connected to duct with forced air flow	Mortar or gypsum. For wall thicknesses inferior to 150 mm, fire resistant cover plates used. ¹⁾ Mineral wool min. 140 kg/m ³ with fire stop mastic min. 1 mm and fire stop coating min. 1 mm. For wall thicknesses inferior to 150 mm, fire resistant cover plates used. ¹⁾
		EI 120 (v _e i↔o) S EI 90 (v _e i↔o) S

(table continues)

1) Refer to [Technical documentation](#) for the details of the installation type / installation system.

(continuation of the table)

<i>Fire separating construction, location of the damper</i>	<i>Installation type, installation system</i>	<i>Performance – class of fire resistance</i>
Solid wall construction – 100 mm min. wall thickness – damper in the wall – not connected to duct, natural convection	With grilles on both sides of the damper. Mortar or gypsum. For wall thicknesses inferior to 150 mm, fire resistant cover plates used. ^{1]}	EI 120 (v _e i↔o)
	With grilles on both sides of the damper. Mineral wool min. 140 kg/m ³ with fire stop mastic min. 1 mm and fire stop coating min. 1 mm. For wall thicknesses inferior to 150 mm, fire resistant cover plates used. ^{1]}	
Gypsum plasterboard wall construction – 100 mm min. wall thickness – damper in the wall – not connected to duct, natural convection	With grilles on both sides of the damper. Mortar or gypsum. For wall thicknesses inferior to 150 mm, fire resistant cover plates used. ^{1]}	
	With grilles on both sides of the damper. Mineral wool min. 140 kg/m ³ with fire stop mastic min. 1 mm and fire stop coating min. 1 mm. For wall thicknesses inferior to 150 mm, fire resistant cover plates used. ^{1]}	

1] Refer to [Technical documentation](#) for the details of the installation type / installation system.

7b.	Declared performances – other essential characteristics	
<i>Essential characteristics</i>	<i>Requirements (provisions of the harmonised standard EN 15650:2010)</i>	<i>Performance (lever or class) / Compliance with the requirements</i>
Nominal activation conditions/sensitivity:	4.2.1.2	Conforms
– sensing element load bearing capacity	4.2.1.2.2	Conforms
– sensing element response temperature	4.2.1.2.3	Conforms
Response delay (response time): – closure time	4.2.1.3	Conforms
Operational reliability: – cycling	4.3.1, a)	50 cycles – conforms
Durability of response delay: – sensing element response to temperature and load bearing capacity	4.2.1.2.2 4.2.1.2.3	Conforms
Durability of operational reliability: – opening and closing cycle tests	4.3.3.2	10 000 + 100 + 100 cycles – conforms

7c. Declared performances – other characteristics		
<i>Characteristics</i>	<i>Technical standard</i>	<i>Performance (lever or class) / Compliance with the requirements</i>
Damper blade tightness	EN 1751:2014	Class 3
Damper casing tightness	EN 1751:2014	Class B

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

In Hostomice, 24 February 2020



Marcel Mandík
CEO
MANDÍK, a.s.